

**\*\*\* IMPORTANT SAFETY RECALL \*\*\***  
**NHTSA Recall No. 21E-075**

Month XX, YYYY

OEM Customer  
XXXX Street Address  
City, ST 12345-6789

Dear Cummins OEM Customer:

We are writing to inform you that Cummins Inc. has determined that a safety-related defect exists in certain 6RBAB, 8RBAB, 10RBAB, 15RBAB generator sets that were manufactured between January 29, 2021 and May 13, 2021. Cummins has initiated a recall of the subject generator sets. Our records indicate that some of these generator sets have been shipped to you.

A copy of Cummins' initial Part 573 Defect Notification report is enclosed. This notification was submitted to the National Highway Traffic Safety Administration (NHTSA) on August 17, 2021. As more fully described in the Defect Notification, certain generator sets are equipped with lifting cables to be used during product assembly or installation. The ferrule on the generator set lifting cable may have been improperly crimped by the supplier.

Enclosed is a list of generator set serial numbers for affected generator sets that our records indicate were shipped to your locations. For generator sets that have left your control, we encourage you to make a safety defect determination in accordance with 49 USC 30118 *et seq.* and, as appropriate, to submit a Defect Notification to NHTSA in accordance with 49 CFR Part 573. Cummins will conduct the recall, including notifying owners pursuant to 49 CFR Part 577, performing the remedy, and submitting quarterly status reports to NHTSA. Cummins is requesting that you provide the associated vehicle model identification, VINs and owner contact information to facilitate owner notification. Please work with your Cummins account team leader to ensure that the requested information is provided to Cummins as soon as possible.

For generator sets that are still in your inventory, please contact your local Cummins Distributor to arrange for this repair. Generator sets can be repaired under TSB210146.

Please note that Federal law prohibits delivery of these generator sets, or vehicles equipped with these generator sets, under a sale or lease until this condition has been remedied.

Cummins apologizes for this inconvenience, but we are initiating this action in the interest of our customers' safety and satisfaction with our products. Thank you for your assistance.

Please confirm receipt of this communication.

Sincerely,

Account Manager

Enclosures:

1. Cummins Part 573 Defect Notification
2. List of generator set(s)