

Part 573 Safety Recall Report

21V-013

Manufacturer Name : KZRV, L.P.

Submission Date : APR 06, 2021

NHTSA Recall No. : 21V-013

Manufacturer Recall No. : KZ-2021-01



Manufacturer Information :

Manufacturer Name : KZRV, L.P.

Address : 0985 N 900W

Shipshewana IN 46565

Company phone : 800-768-4016x154/153

Population :

Number of potentially involved : 806

Estimated percentage with defect : 95 %

Vehicle Information :

Vehicle 1 : 2021-2021 KZ RV Sportsmen Classic

Vehicle Type : TRAILERS

Body Style :

Power Train : NR

Descriptive Information : Circuits run with a 14/2 wire are incorrectly protected by a 20 amp circuit breaker which may result in an increased risk of fire.

Production Dates : OCT 07, 2020 - JAN 11, 2021

VIN Range 1 : Begin :

NR

End : NR

☐ Not sequential

Vehicle 2 : 2021-2021 KZ RV Escape

Vehicle Type : TRAILERS

Body Style :

Power Train : NR

Descriptive Information : Circuits run with a 14/2 wire are incorrectly protected by a 20 amp circuit breaker.

Production Dates : OCT 07, 2020 - JAN 11, 2021

VIN Range 1 : Begin :

NR

End : NR

☐ Not sequential

Vehicle 3 : 2021-2021 KZ RV Sonic

Vehicle Type : TRAILERS

Body Style :

Power Train : NR

Descriptive Information : Circuits run with a 14/2 wire are incorrectly protected by a 20 amp circuit breaker.

Production Dates : OCT 07, 2020 - JAN 11, 2021

VIN Range 1 : Begin :

NR

End : NR

☐ Not sequential

Description of Defect :

Description of the Defect : The microwave circuits are run with 14/2 wire and connected to a 20 amp circuit breaker instead of a 15 amp circuit breaker.

FMVSS 1 : NR

FMVSS 2 : NR

Description of the Safety Risk : If an issue develops, the circuit breaker will not trip and provide adequate protection to the wiring.

Description of the Cause : Production error.

Identification of Any Warning that can Occur : None.

Involved Components :

Component Name 1 : NR

Component Description : NR

Component Part Number : NR

Supplier Identification :**Component Manufacturer**

Name : NR

Address : NR

NR

Country : NR

Chronology :

1/12/2021 - RVIA performed a code inspection of Plant 4 and found the 14/2 wired microwave circuit is incorrectly protected with a 20 amp circuit breaker. All product from Plant 4 in the yard is placed on hold.

1/13/2021 - All units in the yard are inspected and found to have the same issue. These units have the circuit breakers changed to 15 amp circuit breakers.

1/14/2021 - Investigation finds a change in the wiring occurred in October 2020.

1/15/2021 - A safety committee review determines that a recall should be issued.

Description of Remedy :

Description of Remedy Program : Replace the 20 amp circuit breaker with a 15 amp circuit breaker.

How Remedy Component Differs from Recalled Component : NR

Identify How/When Recall Condition was Corrected in Production : All wire circuits are paired with the proper circuit breakers.

Recall Schedule :

Description of Recall Schedule : KZ will notify the dealers and owners of these recreational vehicles by letter. A final copy of the owner letter and dealer repair instructions will be provided to NHTSA.

Planned Dealer Notification Date : MAR 16, 2021 - MAR 16, 2021

Planned Owner Notification Date : MAR 16, 2021 - MAR 16, 2021

* NR - Not Reported